



TEST Reg nr. 361

Ordrenr: 906309
Sagsnavn: Allerslev-og Ammendrup vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Allerslev-Ammendrup Vandværk
Tjørnehoved By 2
4720 Præstø
Att.: Bjarne Jensen

Udskrevet: 07-04-2025
Version: 1
Modtaget: 10-03-2025
Analyseperiode: 10-03-2025 -
31-03-2025
Ordrenr.: 906309

Sagsnavn: Allerslev-og Ammendrup vv
Lokalitet: Allerslev-Ammendrup VV
Prøvested: Ugledigevej 2, 4720 Præstø
Udtaget: 03.02.2025
Prøvetype: Drikkevand - Bek. 221 af 25/2/2025, Gruppe B, Hovedbestanddele
Prøvetager: LAB/HHK
Kunde: Allerslev-Ammendrup Vandværk, Tjørnehoved By 2, 4720 Præstø, Att. Bjarne Jensen

Prøvenr.:	15186/25				
Parameter	Resultat	Enhed	Metode	Grænseværdi	Forbruger taphane jvf BEK 221:2025
Partikler i prøve efter konservering	#	Nej	-	-	
Prøvetagning, Taphane (u. flush)		+	- DS/EN ISO 19458:2006, MST Manual for DRV version 5, 2021, DS/ISO 5667-5:2006		
Lugt	#	Ingen lugt (1)	Ingen	-	Vandet må ikke have en afvigende smag og lugt, desinfektionsmidler undtaget
Smag	#	Ingen (1)	-	-	Vandet må ikke have en afvigende smag og lugt, desinfektionsmidler undtaget
pH ved prøvetagning	8.0	pH	DS/EN ISO 10523:2012	7 - 8.5	Vandet må ikke være kalkaggressivt
Temperatur ved prøvetagning	8.0	°C	-	-	Det bør tilstræbes, at vandet er højst 12°C ved taphanen
Ledningsevne v. ptagning	75.4	mS/m	DS/EN 27888:2003	30 mS/m	Vandets ledningsevne bør som minimum være 30 mS/m ved 25 °C
Intestinale Enterokokker	<1	cfu/100 ml	DS/EN ISO 7899-2:2000	<1	
Kimtal ved 22 °C	2	cfu/ml	DS/EN ISO 6222:2000/Till.1:2002	200	
Coliforme bakterier	<1	cfu/100 ml	DS/EN ISO 9308-1:2014/A1:2017	<1	
E. Coli	<1	cfu/100 ml	DS/EN ISO 9308-1:2014/A1:2017	<1	
Turbiditet	<0.050	FNU	DS/EN ISO 7027-1:2016	1 FNU	
Jern, Fe	<0.010	mg/l	DS/EN ISO 11885:2009	0.2 mg/l	
Mangan, Mn	<0.0020	mg/l	DS/EN ISO 11885:2009	0.05 mg/l	
Natrium, Na+	36	mg/l	DS/EN ISO 11885:2009	175 mg/l	
Ammonium+ammoniak, NH4+	<0.0040	mg/l	DS/ISO 15923-1:2013+DS224:1975Mod	0.05 mg/l	
Nitrit, NO2-	<0.0010	mg/l	DS/ISO 15923-1:2013	0.1 mg/l	
Nitrat, NO3-	1.5	mg/l	DS/ISO 15923-1:2013 + beregning	50 mg/l	
Chlorid, Cl-	49	mg/l	DS/ISO 15923-1:2013	250 mg/l	
Fluorid, F--	0.88	mg/l	DS 218:1975,MOD	1.5 mg/l	
Sulfat, SO4--	45	mg/l	DS/ISO 15923-1:2013	250 mg/l	
Farvetal, Pt	2.2	Pt mg/l	DS/EN ISO 7887 C:2012	15 mg Pt/l	Såfremt kvalitetskravet ved indgang til ejendom er overholdt, kan der tillades højere værdi ved afgang fra vandværk dog maksimalt 15.
NVOC	1.3	mg/l	DS/EN 1484:1997+SM 5310B:2014	4 mg/l	
Bor, B	87	µg/l	DS/EN ISO 11885:2009	1000 µg/l	
Cyanid CN, total	<1.0	µg/l	DS/EN ISO 14403-2:2012	50 µg/l	
Aluminium, Al	<0.50	µg/l	DS/EN ISO 17294-2:2023	200 µg/l	
Antimon, Sb	<0.20	µg/l	DS/EN ISO 17294-2:2023	5 µg/l	
Arsen, As	0.073	µg/l	DS/EN ISO 17294-2:2023	5 µg/l	
Bly, Pb	0.17	µg/l	DS/EN ISO 17294-2:2023	5 µg/l	
Cadmium, Cd	<0.0030	µg/l	DS/EN ISO 17294-2:2023	3 µg/l	
Chrom, Cr	0.033	µg/l	DS/EN ISO 17294-2:2023	25 µg/l	

side 1 af 4

Laboratoriet er akkrediteret af DANAK. Analyseresultaterne gælder kun for de(n) analyserede prøve(r).
Analyserapporten må kun gengives i sin helhed, medmindre skriftlig godkendelse foreligger
Oplysninger om måleusikkerhed findes på www.alsglobal.dk

Tegnforklaring, Resultat:
i.p.: Ikke påvist, -: analysen er ikke udført
i rapporten betyder ikke akkrediteret



TEST Reg nr. 361

Ordrenr: 906309
Sagsnavn: Allerslev-og Ammendrup vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Prøvenr.:	15186/25				
Parameter	Resultat	Enhed	Metode	Grænseværdi	Forbruger taphane jvf BEK 221:2025
Kobber, Cu	0.0083	mg/l	DS/EN ISO 17294-2:2023	2 mg/l	
Kobolt, Co	<0.030	µg/l	DS/EN ISO 17294-2:2023	5 µg/l	
Kviksølv, Hg	<0.0010	µg/l	DS/EN ISO 17852:2008	1 µg/l	
Nikkel, Ni	0.54	µg/l	DS/EN ISO 17294-2:2023	20 µg/l	
Selen, Se	<0.050	µg/l	DS/EN ISO 17294-2:2023	10 µg/l	
Uran, U	<0.020	µg/l	DS/EN ISO 17294-2:2023	10 µg/l	
Zink, Zn	0.013	mg/l	DS/EN ISO 17294-2:2023	3 mg/l	
HS drikkevand	-	-	DS/EN ISO 10301:2000		
HS chlorerede DRV TILLÆG	-	-	DS/EN ISO 10301:2000		
Benzen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
HS chlor. nedbryd.	-	-	DS/EN ISO 10301:2000		
Trichlormethan (Chloroform)	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,1,1-trichlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,1,2-trichlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Trichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Tetrachlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,1,2,2-tetrachlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,1,1,2-tetrachlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Vinylchlorid	<0.020	µg/l	DS/EN ISO 10301:2000	0.5 µg/l	
1,1-dichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
trans-1,2-dichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
cis-1,2-dichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,2-dichlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1.0 µg/l	
Dichlormethan	<0.10	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Epichlorhydrin	*1	<0.050	W-OCPECD01 - GC/MS	0.1 µg/l	
2,6-dichlorphenol	<0.010	µg/l	AK158 - GC/MS	0.1 µg/l	
Pentachlorphenol	<0.010	µg/l	AK158 - GC/MS	0.01 µg/l	
1,2,4-triazol	<0.010	µg/l	AK207 - LC/MS/MS	0.1 µg/l	
Acrylamid	*1	<0.050	Underleverandør - LC/MS/MS	0.1 µg/l	Anvendelse af kemikalier med indhold heraf bør undgås til vandbehandling
Pesticider, Drikkevand grundpakke LC/MS	-	-	LC/MS/MS		
Pesticider, Drikkevand grundpakke GC/MS	-	-	GC/MS		
Pesticider, vand 4 stoffer	-	-	GC/MS		
2,6-DCPP (2-(2,6-dichlorphenoxy-propionsyre)), 2,6-dichlorprop	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
4-CPP, (4-Chlorprop)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Aminomethylphosphonsyre, AMPA	<0.010	µg/l	AK144 - LC/MS/MS	0.1 µg/l	
Atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Bentazon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
2,6-Dichlorbenzamid (BAM)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
ETU (Ethylenthiourea)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Heptachlor	0.025	µg/l	AK158 - GC/MS	0.03 µg/l	
Aldrin	<0.010	µg/l	AK158 - GC/MS	0.03 µg/l	
Heptachlorepoxyd	<0.010	µg/l	AK158 - GC/MS	0.03 µg/l	
Dieldrin	<0.010	µg/l	AK158 - GC/MS	0.03 µg/l	
2,6-dichlorbenzoesyre	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desphenyl-chloridazon, DPC	0.051	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Imazalil	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Methyl-desphenyl-chloridazon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
4-nitrophenol	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
2,4-dichlorphenol	<0.010	µg/l	AK158 - GC/MS	0.1 µg/l	
Desethylatrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desethyl-desisopropylatrazin (DEIA)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desethyl-hydroxy-atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desethylterbutylazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desisopropylatrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desisopropyl-hydroxy-atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Dichlobenil	<0.010	µg/l	AK78 - GC/MS	0.1 µg/l	

side 2 af 4

Laboratoriet er akkrediteret af DANAK. Analyseresultaterne gælder kun for de(n) analyserede prøve(r).
Analyserapporten må kun gengives i sin helhed, medmindre skriftlig godkendelse foreligger.
Oplysninger om måleusikkerhed findes på www.alsglobal.dk

Tegnforklaring, Resultat:
i.p.: Ikke påvist, -: analysen er ikke udført
i rapporten betyder ikke akkrediteret



TEST Reg nr. 361

Ordrenr: 906309
Sagsnavn: Allerslev-og Ammendrup vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Prøvenr.:	15186/25			
Parameter	Resultat	Enhed	Metode	Grænseværdi Forbruger taphane jvf BEK 221:2025
Dichlorprop(2,4-DP)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Didealkyl-hydroxy-atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Pesticider, Frugtavl (Diuron)	-	-	AK78 - LC/MS/MS	-
Diuron	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Glyphosat	<0.010	µg/l	AK144 - LC/MS/MS	0.1 µg/l
Hexazinon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Hydroxyatrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Hydroxysimazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
MCPA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Mechlorprop(MCPP)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Metamitron-desamino	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
PPU (IN 70941), (Nedbr. af Rimsulfuron)	<0.010	µg/l	AK78 - LC/MS/MS	-
Simazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
TFMP	<0.010	µg/l	AK78 - LC/MS/MS	-
Pentachlorbenzen	<0.010	µg/l	AK158 - GC/MS/SIM	-
N,N-Dimethylsulfamid (DMS)	<0.010	µg/l	AK207 - LC/MS/MS	0.1 µg/l
Chlorothalonilamid-sulfonsyre (R417888)	<0.0050	µg/l	AK78 - LC/MS/MS	0,1 µg/l
Pesticider, DRV BEK 221:2025	-	-	- - LC/MS/MS	-
Alachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Dimethachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Dimethachlor OA (CGA 50266)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Metazachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Metazachlor OA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Propachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
t-Sulfinyleddikesyre (Acetochlor SAA)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
CGA 369873 (Dimethachlor metab.)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
[(2,6-Dimethylphenyl)(2-sulfoacetyl)amino]eddikesyre	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Metaldehyd	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
Monuron	<0.010	µg/l	AK78 - LC/MS/MS	-
4-Bis-amido-3,5,6-trichlorobenzenesulfonat (R471811) (Nedbr. af Chlorothalonil)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
6-(tert-Butylamino)-1,3,5-triazine-2,4-diol (CGA324007, LM5, nedbr. af Terbutylazin)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
4-(tert-Butylamino)-6-hydroxy-1-methyl-1,3,5-triazin-2(1H)-one (SYN545666, LM6, nedbr. af Terbutylazin)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
6-Hydroxy-7,7-dimethyl-6,8-dihydroimidazo[1,2-a][1,3,5]triazine-2,4-dion (LM3)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
N,N-Dimethylsulfamidsyre (DMSA)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l
PFAS-forbindelser, Drikkevand	-	-	ASTM D7979-20	-
PFHpA, Perfluorheptansyre	<0.30	ng/l	ASTM D7979-20	-
PFOA, Perfluorooctansyre	0.37	ng/l	ASTM D7979-20	-
PFNA, Perfluorononansyre	<0.10	ng/l	ASTM D7979-20	-
PFNS, Perfluorononansulfonsyre	<0.30	ng/l	ASTM D7979-20	-
PFBS, Perfluorbutansulfonsyre	<0.30	ng/l	ASTM D7979-20	-
PFHxS, Perfluorhexansulfonsyre	<0.10	ng/l	ASTM D7979-20	-
PFOS, Perfluorooctansulfonsyre	<0.10	ng/l	ASTM D7979-20	-
PFDS, Perfluordecansulfonsyre	<0.30	ng/l	ASTM D7979-20	-
PFOSA, Perfluorooctansulfonamid	<0.30	ng/l	ASTM D7979-20	-
PFHxA, Perfluorhexansyre	0.47	ng/l	ASTM D7979-20	-
PFBA, Perfluorbutansyre	<1.0	ng/l	ASTM D7979-20	-
PFHpS, Perfluorheptansulfonsyre	<0.30	ng/l	ASTM D7979-20	-
PFUnDA, Perfluorundecansyre	<0.30	ng/l	ASTM D7979-20	-
PFPeA, Perfluorpentansyre	0.36	ng/l	ASTM D7979-20	-
PFPeS, Perfluorpentansulfonsyre	<0.30	ng/l	ASTM D7979-20	-
PFDA, Perfluordecansyre	<0.30	ng/l	ASTM D7979-20	-
6:2 FTS (6:2 fluortelomersulfonsyre)	<0.30	ng/l	ASTM D7979-20	-

side 3 af 4

Laboratoriet er akkrediteret af DANAK. Analyseresultaterne gælder kun for de(n) analyserede prøve(r).
Analyserapporten må kun gengives i sin helhed, medmindre skriftlig godkendelse foreligger.
Oplysninger om måleusikkerhed findes på www.alsglobal.dk

Tegnforklaring, Resultat:
i.p.: Ikke påvist, -: analysen er ikke udført
i rapporten betyder ikke akkrediteret



TEST Reg nr. 361

Ordrenr: 906309
Sagsnavn: Allerslev-og Ammendrup vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Prøvenr.:	15186/25			
Parameter	Resultat	Enhed	Metode	Grænseværdi Forbruger taphane jvf BEK 221:2025
PFDODA, Perfluordodecansyre	<0.30	ng/l	ASTM D7979-20	
PFTTrDA, Perfluortridecansyre	<1.0	ng/l	ASTM D7979-20	
PFUnDS, Perfluorundecansulfonsyre	<1.0	ng/l	ASTM D7979-20	
PFDODS, Perfluordodecansulfonsyre	<1.0	ng/l	ASTM D7979-20	
PFTTrDS, Perfluortridecansulfonsyre	<1.0	ng/l	ASTM D7979-20	
Sum af 4 PFAS (PFHxS, PFNA, PFOA, # PFOS)	0.37	ng/l	ASTM D7979-20	
Sum af påviste PFAS, 22 stoffer #	1.2	ng/l	ASTM D7979-20	100 ng/L
DEET	<0.010	µg/l	AK78 - LC/MS/MS	
2,6-Dimethylacetanilid (CGA42447)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l

Kommentar

Højst tilladelige værdi er overholdt for de undersøgte parametre.

Underleverandør

*1 ALS Czech Republic s.r.o, CAI L1163

Helle Hornemann

Kopimodtagere:

Teknisk forvaltning Vordingborg Kommune, Valdermarsgade 43, 4760 Vordingborg